



**PUNJAB STATE POWER CORPORATION LIMITED**  
**Office of Chief Engineer/Commercial, Patiala**

ਵਣਜ ਗਸਤੀ ਪੱਤਰ ਨੰ: 27 /2013

ਵੱਲ

ਸਾਰੇ ਇੰਜੀਨੀਅਰ-ਇਨ-ਚੀਫ/ਮੁੱਖ ਇੰਜੀਨੀਅਰਜ਼ (ਵੰਡ)  
ਅਧੀਨ ਪੰਜਾਬ ਸਟੇਟ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਿਟਿਡ ।

2 ਕਾਪੀਆਂ

Memo No. 644/648 / ਐਸ.ਐਸ.ਐਮ-460

Dated: 6/05/2013

**Sub :** **Providing Urban Pattern Supply to Dera/Dhanies having cluster of 3 or more houses and all Dera/Dhanies located within 10 KMs of International Border in State of Punjab.**

For providing Urban Pattern Supply to Dera/Dhanies, ESIM clause 38.2(ii) was amended as per instructions issued vide CC No. 4/2013 dated 10.1.2013. The Para-2 of the Circular provides as under :-

"Urban Pattern Supply shall also be provided against Grant from Punjab Govt. to Dera/ Dhanis having one house or cluster of two houses located within 10 KMs of International Border, situated adjoining to each other and spread over in a stretch of maximum of 300 meters from one end to the other end by providing Single Phase 11 KV line tapped from the nearest UPS feeder and by installing single phase 11 KV, 10 KVA Distribution Transformer.

LT work in respect of above indicated Dera/Dhanies i.e. installation of energy meter and laying of services will be carried out by respective DS Sub-division of the concerned area as per instructions of PSPCL issued from time to time."

Since urban pattern supply is to be provided to all the Deras/Dhanies having One house or Cluster of two houses located within 10 KMs of International Border, the matter has been reviewed to avoid ambiguity & give more clarity in the instructions and as per Resolution passed by Whole Time Directors in its 111<sup>th</sup> meeting held on 17.4.2013, Para No.-2 of EC No. 04/2013 is hereby amended to the extent as to read as under :-

"Urban Pattern Supply shall be provided against Grant from Punjab Govt. to Dera/Dhanies having one house or cluster of two houses located within 10 KMs of International Border by providing Single Phase 11 KV line tapped from the nearest UPS feeder and by installing single phase 11 KV, 10 KVA Distribution Transformer.

However, where two houses in a cluster are situated adjoining to each other and are located in a stretch of maximum 300 meters from One end to the other end, a common single phase 11 KV, 10 KVA Distribution Transformer shall be installed to reduce the capital cost of the project. In all other cases where two houses in a cluster are situated adjoining to each other and are located in stretch of more than 300 meters from one end to the other end, separate single phase 11 KV, 10 KVA Distribution Transformers shall be installed.

The LT work in respect of above indicated Dera/Dhanies i.e. installation of energy meter and laying of services will be carried out by

respective DS Sub-division of the concerned area as per instructions of PSPCL issued from time to time."

• The provisions of ESIM clause No. 38.2(ii) stand amended to the above extent.

*Handwritten signature*  
SE/Sales-1,  
For C.E./Commercial,  
P.S.P..C.L, Patiala.

ਪਿਠ ਅੰਕਣ ਨੰ: 649/889, ਐਸ.ਐਸ.ਐਮ-460

ਮਿਤੀ: 6/5/13

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਹੇਠ ਲਿਖਿਆ ਨੂੰ ਸੂਚਨਾ ਅਤੇ ਲੋੜੀਂਦੀ ਭਾਰਵਾਈ ਲਈ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ:-

- 1) ਚੇਅਰਮੈਨ-ਕਮ-ਮੈਨੇਜਿੰਗ ਡਾਇਰੈਕਟਰ, ਪੰ:ਰਾ:ਪਾ:ਕਾ:ਲਿਮਟਿਡ, ਪਟਿਆਲਾ।
- 2) ਸਾਰੇ ਨਿਰਦੇਸ਼ਕ, ਪੰ:ਰਾ:ਪਾ:ਕਾ:ਲਿਮਟਿਡ, ਪਟਿਆਲਾ।
- 3) ਵਿੱਤ ਕਮਿਸ਼ਨਰ/ ਫਾਇਨਾਂਸ਼ ਟੂ ਗੋਰਮਿੰਟ ਪੰਜਾਬ ਐਂਕਸ-ਆਫੀਸ ਮੈਂਬਰ, ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ, ਚੰਡੀਗੜ੍ਹ।
- 4) ਸਕੱਤਰ/ ਬਿਜਲੀ ਵਿਭਾਗ, ਪੰਜਾਬ ਸਰਕਾਰ, ਚੰਡੀਗੜ੍ਹ।
- 5) ਸਕੱਤਰ, ਪੰਜਾਬ ਸਰਕਾਰ/ਇੰਡ: ਅਤੇ ਕਮਰਸ਼ ਵਿਭਾਗ, ਪੰਜਾਬ ਸਰਕਾਰ, ਚੰਡੀਗੜ੍ਹ।
- 6) ਪ੍ਰੈਜ਼ੀਡੈਂਟ, ਸਟੇਟ ਡਿਸਟ੍ਰਿਬਿਊਟਿਡ ਰਿਡਰੈਸਲ ਕਮਿਸ਼ਨ (ਪੰਜਾਬ) SCO ਨੰ:3009-10, ਸੈਕਟਰ-22, ਚੰਡੀਗੜ੍ਹ।
- 7) ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਚੇਅਰਮੈਨ (ਫੋਰਮ), ਪੀ-1, ਵਾਈਟ ਹਾਊਸ ਰਾਜਪੁਰਾ ਕਲੋਨੀ, ਪਟਿਆਲਾ।
- 8) ਸਕੱਤਰ/ਪੰਜਾਬ ਰਾਜ ਬਿਜਲੀ ਰੈਗੂਲੇਟਰੀ ਕਮਿਸ਼ਨ, ਐਸ.ਸੀ.ਓ.ਨੰ:220-221, ਸੈਕਟਰ-34 ਏ. ਚੰਡੀਗੜ੍ਹ।
- 9) Ombudsman, Electricity Punjab 66 KV Grid Sub-Station, Plot No.A-2, Industrial Area, Phase-1, SAS Nagar (Mohali)-160055.
- 10) ਨਿੱਜੀ ਸਕੱਤਰ ਟੂ ਬਿਜਲੀ ਮੰਤਰੀ, ਪੰਜਾਬ ਸਿਵਲ ਸਕੱਤਰੇਤ, ਪੰਜਾਬ ਸਰਕਾਰ, ਚੰਡੀਗੜ੍ਹ।
- 11) ਮੁੱਖ ਬਿਜਲੀ ਇੰਜੀਨੀਅਰ, ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ।
- 12) ਚੀਫ ਕੋ-ਆਰਡੀਨੇਟਰ, ਉਦਯੋਗ ਸਹਾਇਕ ਡਾਇਰੈਕਟਰ ਆਫ ਇੰਡਸਟ੍ਰੀਜ਼, ਪੰਜਾਬ ਸੈਕਟਰ-17, ਚੰਡੀਗੜ੍ਹ।
- 13) ਨਿਗਰਾਨ ਇੰਜ:./ਆਈ.ਟੀ., ਪੰ:ਰਾ:ਪਾ:ਕਾ:ਲਿਮਟਿਡ, ਪਟਿਆਲਾ ਨੂੰ ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ. ਦੀ ਵੈੱਬ ਸਾਈਟ ਤੇ ਅਪਲੋਡ ਕਰਨ ਹਿੱਤ।
- 14) Dy.CE/Sales-I, Dy.CE/Sales-II & Dy.CE/Billing, P.S.P.C.L., Patiala.
- 15) ਮੁੱਖ ਲੇਖਾ ਅਫਸਰ/ਮਾਲ, ਫਲੈਟ ਨੰ:9, ਸ਼ਕਤੀ ਵਿਹਾਰ, ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ., ਪਟਿਆਲਾ।
- 16) CE/RE&APDRP, PSPCL, Patiala with reference to his Memo No. 6550/53 dated 24/04/2013.
- 17) Under Secy./Meetings, PSPCL, Patiala with reference to his office U.O. No.1259/WTD-Spl.111.1/2013/PSPCL dated 18.4.2013 conveying the WTDs decision against CE/RE&APDRP Memorandum No. 104/DSI-3159 dated 15.04.2013 on the subject noted above.

*Handwritten signature*  
ਵਪੀਕ ਨਿਗ:ਇੰਜ:./ਵਿਕਰੀ-2,  
ਵਾਸਤੇ ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਵੱਟਸ,  
ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ, ਪਟਿਆਲਾ