



PUNJAB STATE POWER CORPORATION LIMITED
(O/O CE/Commercial, Patiala, Ph.No.0175-2214495)
Regd. Office- PSEB Head Office, The Mall, Patiala-147001
Tele Fax: 0175-2210320 email: ce-commercial@pspcl.in

ਵਣਜ਼ ਗਸ਼ਤੀ ਪੱਤਰ ਨੰ: 18/2012

To

ਸਾਰੇ ਇੰਜਨੀਅਰ-ਇਨ-ਚੀਫ/ਮੁੱਖ ਇੰਜਨੀਅਰਜ਼ / ਵੰਡ
ਅਧੀਨ ਪੰਜਾਬ ਸਟੇਟ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਿਟਡ।

Memo No. 510/514 ISR-4/63N-2

Dated: 5/7/2012

Sub:- Amendments in Condition No. 4.1, 7.9, 9.1, 11 and 41.3 of Conditions of Supply.

In view of the PSERC order dated 28/6/12, subject cited conditions of Conditions of Supply have been amended to be read as under:-

Condition No. 4.1 - Low Tension (LT) Supply (Alternating Current 50 cycles)

- (a) Single phase (230 volts between phase and neutral) connections will be released for general load not exceeding 7 kW and motive load not exceeding 2 BHP.
- (b) Three phase (400 volts between phases) connections will be released for motive load exceeding 2 BHP and general load exceeding 7 kW but not exceeding 100 kW including general load of an industrial unit.
- (c) Agricultural power connections and Street Lighting Supply will be released on LT supply voltage.

Condition No. 7.9 - NOC from Punjab Pollution Control Board (PPCB)

An applicant seeking release of load/additional load/demand for Shopping Malls/ Building Complexes / Commercial Complexes/ Approved Residential Colonies or under Industrial Category will submit a No Objection Certificate (NOC), wherever applicable, from the Punjab Pollution Control Board (PPCB) before release of connection/ additional load /demand. However, applicants having small scale industries exempted by PPCB shall be required to submit an affidavit as specified by PPCB.

Condition No. 9.1 - CONNECTED LOAD

For the purpose of computing total connected load, the actual continuous rating of an apparatus / appliance connected to the wiring

Contd...2

will be taken into account. However, the following standard wattage ratings for a consumer of DS/NRS and general loads of other categories of consumers will be adopted for assessing the connected load, if actual rating is not specified by the consumer.

| Category | Light point | Fan point | Wall socket | Power socket (Single phase) | Air Conditioner |
|------------------------------------|------------------------------|---|--|--|---------------------------------------|
| DS/ BS (DS purpose) | 40 Watts (½ to be counted) | 60 watt (½ nd to be counted) | 60 Watts (¼ th to be counted) | 1000 watts (¼ th to be counted) | 2500 watts (1/2 to be counted) |
| NRS/ Industrial /BS (NRS purposes) | 40 Watts (all to be counted) | 60 watts (all to be counted) | 60 watts (½ nd to be counted) | 1000 watts (½ to be counted) | As per name plate (all to be counted) |

NOTES:

- a. 3 phase power sockets for NRS/Industrial purposes will be taken as 6 kW each and half of the no. of sockets will be counted.
- b. Any fraction of lamp/socket/AC will be counted as one.
- c. In case a single switch is used for controlling more than one lamp/ appliance, the sum of the total capacity of all the lamps/appliances will be taken into account for computing connected load.
- d. The load of air conditioners/ AC packages/centralized AC systems bearing ISI mark will be taken as per their nameplate. For non-standard air conditioners, the load of each will be taken as 2.5 KW.

Condition No. 11 ACCEPTANCE OF APPLICATION AND AGREEMENT FORM

Condition No. 11.3 (New)

In case, Contract Demand (CD) exceeds 500 KVA, work for providing the connection may be taken in hand in anticipation of the submission of Test Report, on receipt of a specific request from the applicant. The applicant will also intimate his proposed commissioning schedule and deposit the various charges such as Service Connection Charges, balance Initial Security (if any) etc. as per Schedule of General Charges.

In addition to the specified charges, the applicant shall also have to submit the Test Report within the time period specified in the Demand Notice or seek extension as provided in Condition No.11.4.

After the applicant submits Electrical Contractor's Test Report of the installation, PSPCL will release the connection as per seniority from the date of submission of his test report within the stipulated period as per the Reg. 6.3 of the Supply Code.

In case the applicant is unable to submit Test Report but the work for providing supply of electricity is completed by the PSPCL as per the commissioning schedule given by the applicant, any damage or theft of line/equipment shall be to the account of the concerned applicant after expiry of 15 days from the date of intimation given by the PSPCL to the applicant regarding completion of work.

Condition No. 11.4 (New)

The Demand Notice will be valid for a period of six months for EHT / HT- Industrial/NRS/DS, Agriculture, AP-hightech., Railway Traction, Street lighting and Bulk Supply categories and Three months for other categories namely SP, MS, LT-DS/NRS etc. from the date of issue.

In case, the applicant does not comply within the validity period of Demand Notice his application shall be liable to be cancelled without serving any further notice in this regard. However, if the request for extension in the validity period of Demand Notice is received within the validity period along with extension fee as specified in Schedule of General Charges, validity period will be further extended up to a maximum period of one year from date of issue of demand notice in all cases in blocks of three months by the PSPCL.

Condition No. 41.3 (Clause 30.2 of ESIM)

In the event of death of a consumer, the heirs may apply for the connection to be transferred in the name of one of the heirs. The application will be accompanied by the following documents:

- a) Death certificate
- b) Succession certificate
- c) No objection from other heirs to the connection being transferred in the name of one of the heirs.

In the absence of documents at (a) and (b) above, all the heirs may submit an affidavit duly attested by a Magistrate confirming the death of the consumer, identification of the legal heirs and their consent to the connection being transferred in the name of a particular heir.

Alternatively for Tubewell Consumers, Sajjra Nasad certified by the revenue officers will also be acceptable in place of succession

certificate in the absence of the documents at (a) & (b) above, AE/AEE/Xen/DS, PSPCL concerned will issue notice to arrange gathering of the villagers for seeking/ hearing objections from all the claimants/ legal heirs of the deceased consumers as appearing in the Sajira Nasad and in the same gathering, the connection will be immediately transferred by AE/AEE/Xen/DS, PSPCL in the name of the legal heir(s) in the presence of Gram Panchayat and Nambardar after getting certification on a plain paper regarding death of the deceased consumer from his / her legal heirs/ claimants duly authenticated by the Gram Panchayat/ Nambardar. When this certification will be done in the full gathering of the villagers, there will be no need of any affidavit.

The PSPCL will on the submission of above documents, transfer the connection subject to the condition that charges payable as indicated in the Schedule of General Charges approved by the Commission and the actual cost of providing service where such charges have not been specified, have been deposited by the transferee. The transferee shall also be eligible to get the connection shifted after depositing the specified charges and completion of other formalities.


In case the transfer of the connection is not obtained within 6 months of the death of a consumer, the PSPCL will issue notice requiring that any of the heirs should submit an application for transfer of the connection within 15 days of the service of notice. The connection is liable to be disconnected in case no application is submitted to the PSPCL within the period indicated in the notice.

Existing Domestic consumers having load upto 10KW shall have the option to have single phase supply or three phase supply in case their connected load after computing as per above amended conditions falls within 7KW to 10KW. Existing DS/BS category (DS purpose) consumers may get their load regularized as per condition 9.1 amended as above without levying any load surcharge within a period of 3 months of issue of the public notice, which is being issued separately in leading News Papers. However, Service Connection Charges and Initial Security is liable to be deposited by these consumers for the additional load.

This shall come into force **w.e.f 1st of August, 2012.**

Meticulous compliance of the above instructions may please be ensured.

This issues with the approval of the Competent Authority


Dy. CE/Sales-I,
PSPCL, Patiala.

Contd....5

ਪਿੱਠ ਅੰਕਣ ਨੰ: 515/549 DD/SR - 4/63 IV-2

ਮਿਤੀ: 5/7/2012

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਹੇਠ ਲਿਖਿਆਂ ਨੂੰ ਸੂਚਨਾ ਅਤੇ ਲੋੜੀਂਦੀ ਕਾਰਵਾਈ ਲਈ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ:-

- 1) ਚੇਅਰਮੈਨ-ਕਮ-ਮੈਨੇਜਿੰਗ ਡਾਇਰੈਕਟਰ, ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮ, ਪਟਿਆਲਾ।
- 2) ਸਾਰੇ ਨਿਰਦੇਸ਼ਕ, ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮ, ਪਟਿਆਲਾ।
- 3) ਵਿੱਤ ਕਮਿਸ਼ਨਰ/ਫਾਇਨਾਸ ਟੂ ਗੌਰਮਿੰਟ ਪੰਜਾਬ ਐਕਸ ਆਫੀਸੋ ਸੈਬਰ, ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਿਟਡ, ਚੰਡੀਗੜ੍ਹ।
- 4) ਸਕੱਤਰ/ ਬਿਜਲੀ ਵਿਭਾਗ, ਪੰਜਾਬ ਸਰਕਾਰ, ਚੰਡੀਗੜ੍ਹ।
- 5) ਸਕੱਤਰ, ਪੰਜਾਬ ਸਰਕਾਰ/ਇੰਡ: ਅਤੇ ਕਾਮਰਸ ਵਿਭਾਗ, ਪੰਜਾਬ ਸਰਕਾਰ, ਚੰਡੀਗੜ੍ਹ।
- 6) ਪ੍ਰੋਜੈਕਟ, ਸਟੇਟ ਡਿਸਪਿਊਟ ਰਿਡਰੈਸਲ ਕਮਿਸ਼ਨ (ਪੰਜਾਬ) ਐਸ.ਸੀ.ਓ. ਨੰ: 3009-10, ਸੈਕਟਰ-22, ਚੰਡੀਗੜ੍ਹ।
- 7) ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ ਚੇਅਰਮੈਨ (ਫੋਰਮ), ਪੀ.-1, ਵਾਈਟ ਹਾਊਸ, ਰਾਜਪੁਰਾ ਕਲੋਨੀ, ਪਟਿਆਲਾ।
- 8) ਸਕੱਤਰ, ਪੰਜਾਬ ਰਾਜ ਬਿਜਲੀ ਰੈਗੂਲੇਟਰੀ ਕਮਿਸ਼ਨ, ਐਸ.ਸੀ.ਓ.ਨੰ: 220-221, ਸੈਕਟਰ-34 ਏ, ਚੰਡੀਗੜ੍ਹ।
- 9) Ombudsman, Electricity Punjab 66 KV Grid Sub Stn., Plot no. A-2, Industrial Area, Phase-1, SAS Nagar (Mohali)-160055
- 10) ਨਿੱਜੀ ਸਕੱਤਰ ਟੂ ਬਿਜਲੀ ਮੰਤਰੀ, ਪੰਜਾਬ ਸਿਵਲ ਸਕੱਤਰੇਤ ਪੰਜਾਬ ਸਰਕਾਰ ਚੰਡੀਗੜ੍ਹ।
- 11) ਮੁੱਖ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰ, ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ
- 12) ਚੀਫ ਕੋ-ਆਰਡੀਨੇਟਰ, ਉਦਯੋਗ ਸਹਾਇਕ ਡਾਇਰੈਕਟਰ ਆਫ ਇੰਡੀਸਟਰੀਜ਼ ਪੰਜਾਬ ਸੈਕਟਰ-17, ਚੰਡੀਗੜ੍ਹ।
- 13) ਐਸ.ਈ./ਆਈ.ਟੀ., ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਿਟਡ, ਪਟਿਆਲਾ ਨੂੰ ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ. ਦੀ ਵੈਬ ਸਾਈਟ ਤੇ ਅਪਲੋਡ ਕਰਨ ਹਿੱਤ।
- 14) Dy.CE/Sales-1, Dy.CE/Sales-2 and Dy.CE/Billing, PSPCL
- 15) All Addl SEs / Sr.Xens / AEEs under Commercial organization, PSPCL

ਵਪੀਕ ਨਿਗਮਿੰਟ: ਐਸ.ਆਰ,
ਵਾ: ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਵਣਜ,
ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ., ਪਟਿਆਲਾ।