## PUNJAB STATE POWER CORPORATION LIMITED Office of Chief Engineer / Power Purchase & Regulation, C-3, Shakti Vihar, Patiala–147001

PR Circular No. 09 / 2012

Dated 13 / 09 / 2012

From

The Chief Engineer / PP&R, PSPCL, Patiala.

To

- 1. All The EICs / CEs , DS in PSPCL,
- 2. The Chief Engineer / P&M, PSPCL, Ludhiana
- 3. The Chief Engineer / EA & Enforcement, PSPCL, Patiala
- 4. All The Dy.CEs / SEs, DS in PSPCL
- 5. All The Dy. CEs / SEs, P&M in PSPCL
- 6. All The Dy.CEs, Enf. and MMTS in PSPCL
- 7. All The Addl. SEs / Sr. XENs, DS alongwith 5 spare copies for further distribution amongst their XENs / AEEs / AEs
- 8. All The Addl. SEs / Sr. XENs, P&M Grid Mtc & Distribution
- 9. All The Addl. SEs / Sr. XENs, Enf. and MMTS

Memo. No 6894 / 7034 / PR / LD-38 Dated 13 .9.2012

### **Sub:-** Regulatory Measures on Industry for the month of August-2012.

In view of the gap in demand and supply, the following power Regulatory Measures were announced / circulated to be applicable, starting with effect from 1.8.2012 to onwards, on all general and arc/induction/rolling mill consumers.

Sr. No.	Date of Applicability		Detail of regulatory measures / No. of WoDs (days / duration) Time of duration				
	Appn	Cabinty	Category-2	Category- 2&3	Category-4   Remarks / Regulatory   Measured applicable to		
	From	То	General Consumers	Arc/ Induction Furnace & Rolling Mill Consumers	Continuous process industrial consumers	Category-2, 3 & 4 consumers during normal working days	Telephone Message
1	1.8.12	13.8.12	Peak load exemption for LS & - MS consumers (except essential & other exempted categories). Remained temporarily suspended.			1. Continued from PR Circular 7/12.	503 / 11 dt. 24.7.12 268 / 11 dt. 14.8.12
2	1.8.12	3.8.12 (up to end of peak load hours)	3 (72 Hrs.) 08:00 hrs. to 08:00 hrs. of 3 <sup>rd</sup> day	4 (96 hrs.) w.e.f. end of peak load hrs. of previous day to end of peak load hrs. of 4 <sup>th</sup> day	Load allowed up to peak load exemption only.	Continued from PR circular 7/12	508 / 11 dt. 24.7.12 100 / 11 dt. 29.7.12

	2012	60.10	1 (0.4.1 )	1 (241 )	1		206/11
3	3.8.12	6.8.12	1 (24 hrs.)	1 (24 hrs.)	-do-	1. 11 hrs. day time power	296 / 11 dt.
	end of		08:00/ 08:30	08:00/ 08:30		allowed to the consumers	3.8.12
	peak		to 08:00/	to 08:00/		between 08:00 to 19:00	
	load		08:30 of next	08:30 of next		hrs. for all zones except	
	hrs.		day	day		central and 08:30 to 19:30	
						hrs. to central zone	
						2. During night hrs.	
						between 22:00 to 08:00 hrs. & between 22:30 to	
						08:00 hrs. (central zone). 10% of SCD is allowed to	
						the consumers. 3. During peak load hrs. of	
						normal working days, only	
						restricted load is allowed to	
						be used by the consumers.	
5	7.8.12	13.8.12	1 (23 hrs.)	1 (23 hrs.)	-do-	1. 12 hrs. day time power	370 / 11 dt.
	7.0.12	13.0.12	08:00 to	08:00 to	-uu-	allowed to the consumers	6.8.12
			07:00 of next	07:00 of next		between 07:00 to 19:00	0.0.12
			day and 08:30	day and 08:30		hrs. for all zones except	
			to 7:30 hrs. of	to 7:30 hrs. of		central and 07:30 to 19:30	
			next day	next day		hrs. to central zone	
			(Central	(Central		2. During night hrs.	
			zone)	zone)		between 22:00 to 07:00	
						hrs. and between 22:30 to	
						07:30 hrs. (central zone).	
						10% of SCD is allowed to	
						the consumers.	
						3. During peak load hrs. of	
						normal working days, only	
						restricted load is allowed to	
						be used by the consumers.	
6	14.8.12	16.8.12	Relaxed	Nil - For	Relaxed	1. Arc furnace consumers	268 / 11 dt.
				induction &		during normal working	14.8.12 &
				rolling Mill		days can use PSPCL	290 / 11 dt.
				3 (72 hrs.) for		power.	14.8.12
				Arc furnace		2. Category 2 & 3	
				consumers		consumers can use 50%	
				between		peak load exemption w.e.f.	
				08:00 hrs. to		14.8.12.	
				08:00 hrs. of		3. 100% peak load	
				3 <sup>rd</sup> day		exemption is allowed to be	
7	17.0.10	21.0.12	1.	1.	1.	used w.e.f. 15.8.12	260 / 11 1:
7	17.8.12	21.8.12	-do-	-do-	-do-	LS & MS consumers fed	369 / 11 dt.
						from category-2 can use	17.8.12
						load during night hours	
						between 22:00 to 7:00 hrs./	
						22:30 to 7:30 hrs. MS consumers to restrict the	
						load during PLRH to 10% of connected load.	
8	22.8.12	28.8.12	-do-	Relaxed	-do-		543 / 11 dt.
0	22.0.12	20.0.12	-u0-	Relaxed	-uo-	MS category consumers to restrict the load during	22.8.12
						PLRH to 10% of connected	44.0.14
						load.*	
*D						10ad. **	

<sup>\*</sup>Restriction imposed on MS category consumers relaxed w.e.f. 29.8.12 vide Msg. No. 141/11 dt. 29.8.12

# **Special Instructions**

Peak load exemptions to LS & MS category consumers fed from category-1 feeder, also remained suspended w.e.f. 1.8.2012 to 13.8.2012 and was relaxed as per sr. no. 6 (above table) remarks 2 & 3.

- 2. These regulatory measures are not applicable to Essential & other exempted category of consumers fed from Cat-2&3 feeders as mentioned in PR circular 12/98 and 6/2010.
- 3. Restricted Load up to the limit of 10% of the SCD is allowed to be used by category-2 & 3 consumers on their WOD/ restricted hours only.
- 4. The consumers can import Open Access power on their WODs as per their open Access agreements.
- 5. During suspension of peak load exemption for LS and MS consumers w.e.f. 24.7.12 onwards, the consumers are allowed to import open access power to the extent of peak load granted. The suspension is valid only for the use of PSPCL power.
- 6. Peak load exemption charges are not to be levied for the period during which peak load exemptions remained suspended, however the said charges are to be levied on prorate basis for the period during which peak load exemptions remained curtailed.
- 7. Days of weekly off day remains the same as mentioned in PR Circular No. 2/2010

#### **General Instructions**

- 1. The consumers are requested to download the information regarding peak load restrictions/ weekly off days from the PSPCL website. They are requested to visit the website of the PSPCL on regular basis, in future.
- 2. The field officers were requested to display the relevant circulars on the notice Boards of complaint centers as well as Sub Divn offices/Grid Sub Stations.

This circular can also be downloaded from PSPCL Website www.pspcl.in

This issues with the approval of Competent Authority.

Sd/ Dy. Chief Engineer/PR
for Chief Engineer/PP&R,
PSPCL, Patiala.

### CC:-

- 1. The Chairman-cum-Managing Director & All Directors of PSPCL
- 2. The Secretary, Punjab State Electricity Regulatory Commission, 220–21 Sector–34A, Chandigarh.
- 3. The OSD to Chairman, PSPCL, Patiala
- 4. The Er. in-Chief / Commercial, PSPCL, Patiala. He is requested to make the necessary amendments in the relevant clause of ESIM-2010.
- 5. The SE / Technical, PSPCL, Patiala. He is requested to endorse the same to Dy. Secretary/ Services-III and Dy. Secy / Tech I, II & III PSPCL, Patiala.
- 6. The SE / IT, PSPCL, Patiala for uploading this circular on PSPCL Website.
- 7. The Addl. SEs / Sr. XENs, CBC, PSPCL, Patiala, Ludhiana & Jalandhar.