

GURU GOBIND SINGH SUPER THERMAL PLANT, RUPNAGAR

Enquiry No. 179 / CHP-M2 / GGSSTP Dated: 07/01/2026 Due on: 02/01/2026

"PERFORMA FOR QUOTING THE RATES"

Sr. No.	GGSSTP Code No	Description of material	Qty. (Set)	Per unit Rate (Rs.)
1.	14030128	Toothed Ring Hammers for Stage-I Ring granulators TRM-54 as per drawing/specification as Annexure-I & IIa weight of one hammer=30 kg. \pm 5%. One set = 78 nos. hammers. Weight of one set = $78 \times 30\text{kg} = 2340\text{kg}$ ($\pm 5\%$ variation in weight of each hammer is allowed)	01	


Signature of Bidder

Note: -

- i) The Rates quoted shall be firm & the rates of taxes/duties should be clearly indicated in the quotation, if not indicated the same will be treated as inclusive of all taxes and duties.
- ii) The validity period of offer should be at least 120 days from the date of opening of Tender.


Annexure-I
Specification Sheet

1. Toothed Ring Hammers for stage-I Ring granulator TRM-54 as per drawing/specification as annexure-I&IIa (weight of 1 Hammer=30 kg $\pm 5\%$) one set= 78 no's. (Weight of one set=78x30=2340 kg) ($\pm 5\%$ variation in weight is allowed).
2. Tolerance: - As per IS 4897 class 2nd.
3. Material: - Mn steel as per IS276(2000) Grade-3rd.
4. Test Reports only from NABL Accredited lab are acceptable at the time of inspection at firm premises. If defects develop in material on testing on-load/ no-load after installation, the firm will resupply the complete material free of cost with the test reports of NABL accredited lab only.
5. Final Inspection will be carried out at GGSSTP main store.
6. Quotation of only those firms should be considered who are themselves manufacturer of crusher spares and has delivered material of Secondary crusher of 750 to 1000 TPH capacity in the past to GGSSTP, GHTP, GNDTP, NTPC only.



ASE/CHPM-II
GGSSTP, Rupnagar


Paninder Singh
AE/CHPM-II
GGSSTP, Rupnagar

NOT TO SCALE



ANNEXURE - I a



Tolerance \div As per IS - 4897 Class - IInd

Material \div Mn. STEEL As per - 276 (2000) Grade - III

7/1/20
Er. J.S. Mann
Addl. Superintending Engineer,
Coal Handling Plant Mtc-2,
GGSSTP Roopnagar

Parminder Singh
Er. Parminder Singh (111311)
Assist. Engineer/CHPM-2
GGSSTP Roopnagar

50
100