



PSPCL

Powering Punjab
enriching Lives

"Punjab State Power Corporation Limited"
(Regd. Office: PSEB Head Office, the Mall Patiala-147 001)
Office of: Superintending Engineer,
Coal Handling Plant, GGSSTP, Roopnagar-140 113.
Corporate Identity No.U40109PB2010SGC033813
Phone No. 96461-07211
E-mail: se-chp-ggsstp@pspcl.in

To

The Joint Secretary/Computerization ,
PSPCL, The mall, Patiala-147001,
Email: tender@pspcl.in .

Memo No. 39/CHPM/CE/CHP
Date: 07 /01/2026

Subject: - Upload of Limited Tender (Short Term) on PSPCL's Website.

Please find herewith the attachment through Email of the following tender
issued by this office for uploading the same on the PSPCL's website immideately.

Sr. No.	Tender Enquiry No. and date	Estimated cost	Remarks
1	179/CHPM-2/GGSSTP	Rs. 3,15,060/- including taxes	NIT

DA: As above


Deputy Chief Engineer,
Coal Handling Plant,
GGSSTP, Ropar

(P-6)
1

PUNJAB STATE POWER CORPORATION LIMITED

To

M/s _____

Memo No: _____ /CHPM-II Dated: _____ /01/2026

Subject: -Procurement of Ring Hammers for Ring Granulators (Secondary Crushers) of CHP Stage-I.

Enquiry No. 101 /CHP/M-2/GGSSTP Dated: 07 / 01 / 2026

1	Last date and time of receipt of tender	22/01/2026 Up to 11.00 AM
2	Date and time of opening of tender	22/01/2026 AT 11.30 AM

(Note: - In case opening date happens to be holiday, tender shall be opened on next working day at the same time).

Dear Sir,

Please send your sealed quotation in duplicate as per Performa attached, with firm prices for supply & delivery of items as detailed in Annexure-A enclosed. Enquiry Number & date of opening of tender must be legibly mentioned at top right corner of sealed cover. General terms & conditions shall be as per Annexure-B attached. Unit rate should be quoted strictly on the Performa given in Annexure-C. Please note that if quoted rates are not as per attached Performa, the offer is liable to be rejected, Insurance and freight charges should be quoted separately.

The offer must have validity period of at least 120 days as per clause-6 of Annexure- B & C attached.

Yours faithfully,


Dy. Chief Engineer,
Coal Handling Plant,
GGSSTP, Roopnagar.

CC

1. Dy. C.A.O., O&M, GGSSTP, Roopnagar
2. Notice Board.

PUNJAB STATE POWER CORPORATION LIMITED
GURU GOBIND SINGH SUPER THERMAL PLANT, ROOPNAGAR


Enquiry No. 131 Dated: 07/01/2026 Due on: 22/01/2026

"Detail of material & Technical Specification"

Sr. No.	GGSSTP Code No	Description of material	Qty. (Set)
1.	14030128	Toothed Ring Hammers for Stage-I Ring granulators TRM-54 as per drawing/specification as Annexure-I & IIa weight of one hammer=30 kg. \pm 5%. One set = 78 nos. hammers. Weight of one set = $78 \times 30\text{kg} = 2340\text{kg}$ ($\pm 5\%$ variation in weight of each hammer is allowed)	01

Terms & Conditions: -

1. The rates should be quoted on FOR destination basis.
2. Offer should be supplied in sealed envelope super scribbling enquiry no. on top of it.
3. Any deviation from PSPCL standard terms & conditions be clearly mentioned in quotation under schedule of deviation otherwise all terms and conditions will be deemed to have been accepted.
4. Telegraphic tender shall not be accepted.
5. Qty. can be increased or decreased.
6. Random testing of material on receipt at GGSSTP store, irrespective of the fact whether or not it was inspected before dispatch, can be carried out by PSPCL. In case of any failure the entire lot shall be rejected at the risk and cost of the supplier.
7. The offer should be kept valid for 120 days.
8. The supply /delivery of material must be within 60 days from date of issue of Purchase Order.
9. Competent authority may distribute the qty. to more than one firm.
10. Any firm offering discount on quoted price after opening the tenders will be out rightly rejected.
11. The Drawing is tentative for quoting rates. The firm should see the sample at GGSSTP site for proper material and dimensions. The firm shall give guarantee for fitment of material procured in mother equipment.
12. All other general terms and conditions as per Annexure-B attached.
13. Quotation of only those firms should be considered who are themselves manufacturer of crusher spares and has delivered material of Secondary crusher of 750 to 1000 TPH capacity in the past to GGSSTP, GNDTP, GHTP and NTPC only.
14. Test Reports only from NABL Accredited lab are acceptable at the time of inspection at firm premises. If defects develop in the material on testing on-load after installation, the firm will resupply the complete material free of cost with the test reports of NABL accredited lab.


8/1/26
Sr.Xen/CHPM-II
GGSSTP, Rupnagar