

ANNEXURE-'A'

Enquiry No. 1887 /V&A/O&M/PC-2757
Dated: 06-01 -2026
Due on 06-02 -2026

SCHEDULE OF REQUIREMENT

| Sr. No. | GHTP Store Code | Description of Material | Unit | Qty. Required |
|---------|-----------------|--|------|---------------|
| | | Temperature switch (Technical Specifications as per Annexure-1) | | |
| 1 | 25104526 | Range: 120°C to 215°C, Capillary Length: 8 meter, Max Bulb Temperature:260°C | No. | 02 |
| 2 | 25104527 | Range: 25°C to 90°C, Capillary Length: 8 meter, Max Bulb Temperature:300°C | No. | 09 |

Notes:-

- (i) The firm must have **GST Registration number & PAN No.** and same should be provided while quoting the rates. If the firm is registered under 'Composite Levies' then the same should be clearly mentioned in the quotation.
- (ii) The firm must provide HSN Code in price schedule Performa in Annexure' C'.
- (iii) Bidder have to submit the documentary evidence (Latest copy of memorandum of Micro Small & Medium Enterprises field under section-8 of MSMED Act, 2006 duly acknowledged by competent authority) of being a Micro, Small & Medium Enterprise, If the bidder does not submit the proof at the time of submission of its bid, it shall be considered as a Large Enterprise.
- (iv) Tax Rate as provided in quotation shall be final.
- (v) Any change in GST Rate after the submission of quotation and before the supply (with in delivery period) will be in PSPCL account. However no extra payment on account of increase in GST Rate after the delivery period or supply of material will be made whichever is earlier.
- (vi) Due to misclassification of HSN code increase in tax will be in supplier account. However due to misclassification of HSN code decrease in tax will be refunded to the PSPCL.

2. Negotiations, if at all required, shall be held only with the lowest tenderer.
3. Rates should be quoted by the suppliers in their quotations both in figures as well as in words as per Annexure-'C'.
4. Attached price break up schedule must be filled and prices must be type written.

5. For Tendering value less than Rs. 5 lac EMD will not be applicable. Tendering value Rs. 5 Lac and above EMD @2% of the Tender value rounding to the multiple of Rs. 10/- on higher side subject to minimum of Rs.10,000/- and maximum of Rs. 20 Lac.
Note:- Tender value is to be considered including all taxes and other charges. EMD will be applicable on Standardized Firms also.

6. SECURITY DEPOSIT- The successful Tenderers shall be required to submit Security deposit for faithful execution of the purchase order/Contract of value exceeding Rs. 1,00,000/- at the rate of three percent (3%) of ordered value rounded off to a multiple of Rs. 10/- on the higher side. Tenderers exempted from EMD up to Rs. 5.0 Lac will have to submit security deposit for Purchase Orders valued above 1.0 Lac.

Note:- As security deposit will not be applicable on supply of proprietary items and firms supplying material under DGS& D rate contract. Security deposit will be applicable on Standardized Firms also.

7. The payment will be made through RTGS system of digital payments only instead of Cheque/DD. The firm must submit Bank A/c details with the quotation.

8. Your quotation must be valid for at least 120 days from the date of opening.

9. Hand written/conditional quotation shall not be accepted.

10. All other terms and conditions of Annexure-B (attached) and PSEB/PSPCL Purchase Regulations, 2017, amended upto date, shall be applicable.

11. The firm should not be blacklisted by PSEB/PSPCL or any other Govt. Deptts./ Organizations.

12. Quantity mentioned in schedule of requirement can be divided and ordered on more than one supplier.

13. The quotation/tender may be submitted either in person or through registered post but not through courier as courier service is not available at GHTP, Lehra Mohabbat.

14. "TDS u/s 194Q of Income Tax Act shall be deducted, as applicable."

IMPORTANT NOTE:-

**EMD IS PAYABLE THROUGH CASH RECEIPT, DEMAND DRAFT OR
THROUGH RTGS AT LEHRA MOHABBAT/RAMPURA PHUL IN
FAVOUR OF AO/O&M,GHTP, LEHRA MOHABBAT SBI A/C NO.
55069843647, IFSC CODE: SBIN0050840.**

For

Superintending Engineer/HQ,
Chief Engineer/O&M
GHTP, Lehra Mohabbat.

ANNEXURE-1

General Technical Specifications of Temperature switch

| | | |
|----|-----------------------|---|
| 1 | Enclosure | : Die cast Aluminium Enclosure Weather Proof to IP 66 |
| 2 | Elect. Rating | : 125 VAC, 125 DC, 250VDC |
| 3 | Switch Type | : 1 No. SPDT |
| 4 | Repeatability | : $\pm 1\%$ FSR |
| 5 | Mounting Type | : Remote Panel Mounting with provision of Nut & Bolts (Flexible Capillary) |
| 6 | Cable Entry | : $\frac{1}{2}$ " NPT cable entry through aluminium/SS adapter/Cable Gland |
| 7 | Process connection | : $\frac{1}{2}$ " BSP (M) brass/SS bulb pocket 111mm length |
| 8 | Sensing element | : Tin plated copper bulb & copper capillary with 304SS armoring on capillary. |
| 9 | Material | : 316SS |
| 10 | Switch setting | : 5 to 95% FSR, There must be adjustable differential (hysteresis) from 10° to 30°C |
| 11 | Accessories | : Any additional adaptors for process connection /cable entry are required that to be supplied as a part of switch. |
| 12 | Tolerance in range | : Allowed subject to fulfillment of other specifications. The switch quoted to be calibratable within 5 to 95% of our required range. |
| 13 | Process Fluid | : Oil, Air, Water |
| 14 | Accuracy | : $\pm 3^\circ$ to 5°C |
| 15 | Operating Temperature | : As per our requirement, Media Temp. upto 300°C for sensor bulb, Ambient Temp. upto 70°C |

S.Kumar
01/01/2018Date:
M:
Year: