

**ANNEXURE-'A'**Enquiry No. 1911 /AHP/O&M/PC-2774Dated: 27-2-2026Due on 30-03-2026**SCHEDULE OF REQUIREMENT**

Sr. No.	GHTP Store Code	Description	Unit	Qty. Required
A		<b>Pressure Gauges : MAKE – H. GURU, Wika, Forbes Marshal, Baumer</b> <b>Accuracy : +/- 1% of FSD</b> <b>Sensing elements : Bourdon</b> <b>Bourdon Materials : SS 316L</b> <b>Block Materials : SS 316</b> <b>Movement Materials: SS 304</b> <b>Case Materials : SS 304, Bayonet type. Weather Proof as per IP-67</b> <b>Bezel : SS 304, Bayonet type</b> <b>Standard Fitments : Micro Zero Adjustable Pointer, Blow out Disc.</b> <b>Over Range Protn, : 130% of FSD</b> <b>Joint : ARC Argon Welding</b> <b>Window : Glass</b>		
1	30152801	Type Bourden Range 0-25 kg/cm <sup>2</sup> Dial size 150mm Connection ½", BSP (M) Mounting Direct Bottom Entry Glycerin filled	No	05
2	80152813	Type Bourden Range 0-2 kg/cm <sup>2</sup> Dial size 150mm Connection ½" BSP (M) Mounting Direct Bottom Entry	No.	06
B		<b>MAKE – H. GURU, Wika, Forbes Marshal, Baumer</b> <b>Accuracy : +/- 2% of FSD</b> <b>Dial size : 63 mm</b> <b>Connection : 1/4" BSP (M)</b> <b>Sensing elements : Bourdon</b> <b>Bourdon Materials : SS</b> <b>Block Materials : SS</b> <b>Movement Materials : SS</b> <b>Mounting : Centre Back entry</b> <b>Case Materials : SS</b> <b>Window : Glass</b>		
1	80152814	Type Bourden Range 0-10 kg/cm <sup>2</sup> Dial size 63mm Connection ¼" BSP (M) Mounting Centre Back Entry	No.	50

2	80152815	Type Bourden Range 0-6 kg/cm <sup>2</sup> Dial size 63mm Connection ¼" BSP (M) Mounting Centre Back Entry	No.	20
C		<b>TEMPRATURE GAUGES MAKE – H. GURU, Wika, Forbes Marshal, Baumer</b> Type : Bi-Metallic Accuracy : +/- 1% of FSD Case : SS Bayonet type. Weather Proof as Per IP-67, Bezel : SS 304, Bayonet type Bulb/Stem Matl. : AISI SS 316 Bulb/Stem Dia : 8 mm. Mounting : Bottom entry Stem. Length : 150 mm Std. fitments : Micro zero Adjustable pointer, Over Range Protn : 125 of FSD Window : Glass		
1	80152856	Type Stem Range 0-200 <sup>o</sup> C Dial size(mm) 100 Connection 1/2" , BSP (M) Mounting Bottom Entry	No	05
2	30152853	Type Stem Range 0-100 <sup>o</sup> C Dial size(mm) 100mm Stem Dia – 6mm Connection 1/2" , BSP (M) Mounting Bottom Entry	No.	03
D		<b>MAKE – H. GURU, Wika, Forbes Marshal, Baumer</b> Type : Mercury filled Accuracy : +/- 1% of FSD Connection : ½" BSP (M) With Adjustable Bourdon : SS 316L Movement : SS 304 Case : SS 304, Bayonet type. Weather Proof as Per IP-67, Scale : Black lettering on white background in 270 oC Bulb/Stem Matl. : SS 316 Bulb/Stem Dia : 10 mm. Bulb/Stem length : 100mm Mounting : Bottom entry Stem Length : As per table Capillary Length : 3 Meters Capillary Type : SS Capillary Covered With SS 304 Sheath Std. fitments : Micro zero Adjustable pointer, Window : Glass		

1	80152851	Type Capillary Range 0-300 <sup>o</sup> C Dial size(mm) 100 Connection 1/2" , BSP (M) Mounting Back Entry	No.	03
2	80152853	Type Capillary Range 0-100 <sup>o</sup> C Dial size(mm) 100 Connection 1/2" , BSP (M) Mounting Back Entry	No	05

**Notes:-1.** (i) The firm must have GST Registration number & PAN No. and same should be provided while quoting the rates. If the firm is registered under 'Composite Levies' then the same should be clearly mentioned in the quotation.

(ii) The firm must provide HSN Code in price schedule Performa in Annexure 'C'.

(iii) Bidder have to submit the documentary evidence (Latest copy of memorandum of Micro Small & Medium Enterprises filed under section-8 of MSMED Act, 2006 duly acknowledged by competent authority) of being a Micro, Small & Medium Enterprise, If the bidder does not submit the proof at the time of submission of its bid, it shall be considered as a Large Enterprise.

(iv) Tax Rate as provided in quotation shall be final.

(v) Any change in GST Rate after the submission of quotation and before the supply (with in delivery period) will be in PSPCL account. However no extra payment on account of increase in GST Rate after the delivery period or supply of material will be made whichever is earlier.

(vi) Due to misclassification of HSN code increase in tax will be in supplier account. However due to misclassification of HSN code decrease in tax will be refunded to the PSPCL.

2. Negotiations, if at all required, shall be held only with the lowest tenderer.
3. Rates should be quoted by the suppliers in their quotations both in figures as well as in words as per Annexure-'C'.
4. Attached price break up schedule must be filled and prices must be type written.
5. **For Tendering value less than Rs. 5 lac EMD will not be applicable. Tendering value Rs. 5 Lac and above EMD @2% of the Tender value rounding to the multiple of Rs.10/- on higher side subject to minimum of Rs.10,000/- and maximum of Rs. 20 Lac.**  
**Note:- Tender value is to considered including all taxes and other charges. EMD will be applicable on Standardized Firms also.**
6. **SECURITY DEPOSIT-** The successful Tenderers shall be required to submit Security deposit for faithful execution of the purchase order/Contract of value exceeding Rs. 1,00,000/- at the rate of three percent (3%) of ordered value rounded off to a multiple of Rs. 10/- on the higher side. Tenderers exempted from EMD up to Rs. 5.0 Lac will have to submit security deposit for Purchase Orders valued above 1.0 Lac.  
**Note:- As security deposit will not be applicable on supply of proprietary items and firms supplying material under DGS& D rate contract. Security deposit will be applicable on Standardized Firms also.**
7. **The payment will be made through RTGS system of digital payments only instead of Cheque/DD. The firm must submit Bank A/c details with the quotation.**
8. **Your quotation must be valid for at least 120 days from the date of opening.**
9. Hand written/conditional quotation shall not be accepted.

10. All other terms and conditions of Annexure-B (attached) and PSEB/PSPCL Purchase Regulations, 2017, amended upto date, shall be applicable.
11. The firm should not be blacklisted by PSEB/PSPCL or any other Govt. Deptts./ Organizations.
12. Quantity mentioned in schedule of requirement can be divided and ordered on more than one supplier.
13. The quotation/tender may be submitted either in person or through registered post but not through courier as courier service is not available at GHTP, Lehra Mohabbat.
14. "TDS u/s 194Q of Income Tax Act shall be deducted, as applicable."

**IMPORTANT NOTE:-**

**EMD IS PAYABLE THROUGH CASH RECEIPT, DEMAND DRAFT OR THROUGH RTGS AT LEHRA MOHABBAT/RAMPURA PHUL IN FAVOUR OF AO/O&M,GHTP, LEHRA MOHABBAT SBI A/C NO. 55069843647, IFSC CODE: SBIN0050840.**

  
For Superintending Engineer/HQ,  
Chief Engineer/O&M  
GHTP, Lehra Mohabbat.